

	<u>Appendix 2 - Quarterly Legionella Reporting</u>	April -June 2015
1.	Number of confirmed legionella outbreaks - two or more confirmed cases in short period as defined by the Health Protection Agency	None
2.	Number of known PCC managed properties with an out of date risk assessment (also provide details of and the reasons why).	7 (3 - due to lack of response from School Head, 1 x postponed due to change in site manager, 1 x Assessment postponed due to major project works, 2 x delayed due higher priority legionella support to other Services)
3.	Number of Legionella risk assessments completed this quarter by a contractor	32
4.	Number of Legionella risk assessments completed this quarter in House .	35
5.	Audit samples detecting Legionella and actions arising.	Central Library 637 cfu (water system under review & further sampling) identified some very minor design faults which may be dealt with if further samples are positive Corben Lodge 2000 cfu (water system review and further sampling) identified some very minor design faults which may be dealt with if further samples are positive Edinburgh house 822 cfu & 708 cfu (water system review, increased flushing regime and further sampling) Major water system design issues awaiting <i>further sample results. Consider options for disinfection</i>
6.	Total amount spent on legionella prevention & monitoring measures this quarter.	£88,909
8.	Total Number of staff receiving Legionella training this quarter.	82

9.	Exceptions arising from any third party audit completed.	None
----	--	------